

**Property:**

P-0982 Thurrock  
 Engineering Supplies Ltd  
 - Unit 1 Motherwell Way,  
 RM20 3XD  
 Unit 1 Motherwell Way,  
 RM20 3XD, Grays, United  
 Kingdom

**Client:**

Thurrock Engineering  
 Supplies Ltd

**Task:**

T-04360

**Issued by:**

Johanne Collins  
 19th May 2026

**Performed Date:**

13th May 2026

## Scope of Works

Fire Extinguishers: Annual (16)

## Servicing Summary

Service	Asset	Quantity
Fire Extinguishers: Annual	Fire Extinguishers - Portable	13

## Maintenance

### Fire Extinguishers: Annual

BS 5306-3 2017

Asset	Status
020 - CO2 2.0 KG - Portable Fire Extinguisher Mezz floor near stairs from warehouse	PASS
019 - AFFF 6.0 L - Portable Fire Extinguisher Mezz floor near stairs from warehouse	PASS
017 - AFFF 6.0 L - Portable Fire Extinguisher Rear stairs fire exit	PASS
010 - CO2 2.0 KG - Portable Fire Extinguisher Upstairs office corridor	PASS
009 - CO2 2.0 KG - Portable Fire Extinguisher Far rear right fire door	PASS
008 - CO2 2.0 KG - Portable Fire Extinguisher Front entrance door	PASS


Asset		Status
007 - CO2 2.0 KG - Portable Fire Extinguisher	Rear right fire door	PASS
006 - CO2 2.0 KG - Portable Fire Extinguisher	Warehouse near shutter	PASS
005 - AFFF 6.0 L - Portable Fire Extinguisher	Far rear right fire door	PASS
004 - AFFF 6.0 L - Portable Fire Extinguisher	Upstairs office corridor	PASS
003 - AFFF 6.0 L - Portable Fire Extinguisher	Front entrance door	PASS
002 - AFFF 6.0 L - Portable Fire Extinguisher	Rear right fire door	PASS
001 - AFFF 6.0 L - Portable Fire Extinguisher	Warehouse near shutter	PASS

### Technician Notes

Preventative maintenance

### Signoff

Maintenance has been carried out in accordance with the relevant British Standards.

Technician	Date/Time	Accreditations	Signature
Stuart Sims	13th May 2026 12:09PM	Fire Extinguisher Servicing: Gate Automation Servicing: Access Control Servicing: CCTV Servicing: Intruder Alarm Servicing: Working with Children Check: Police Checked: Fire Alarm Servicing: Enhanced DBS Checked:	

## Signatures

13th May 2026: A client signature could not be obtained due to: Not available

### Company Accreditations:

NSI Gold (Security) & NSI Fire Gold (Fire) - 3043

BAFE - 52046

FIA - 1176

Gate Safe - 2115

SMAS Worksafe - 159027